

**GAS AND WATER REPORT**  
**BY PUBLIC WORKS DIRECTOR MICHAEL BENNETT**  
**July 16, 2021 through August 12, 2021**

**In the Water Department:**

- Changed meters
- Worked on repairs
- Took routine water samples
- Changed daily totalizer chart
- Calculated daily usage
- Took chlorine residuals
- Swept and mopped water plant
- Replaced a leaking service line 917 S. State under highway
- Took THM & HAA water samples, good results in compliance
- Finished painting hydrants
- Completed flushing all hydrants

**In the Gas Department:**

- Changed meters
- Worked on repairs
- Changed daily high/low charts
- Checked odorizer daily
- Patrolled gas system
- Cut off gas service 117 Ellsworth at main, house will be torn down
- Cut off gas service 214 W. Short, house burnt
- Took Cathodic readings in all sections of gas system, all readings good
- Had town regulator stations and main relief tested
- Repaired an underground gas leak on a tap at 3 Rue Le Petite

**In Other Business:**

- Mowed Grass
- Put down weed killer
- Had 2019 Gas and Water truck serviced oil changed
- Will be shutting off delinquent accounts

**In Village Business:**

- Basketball court & backboards painted
- Repaired backboard due to vandalism
- Put up new heavy duty basketball hoops
- Put up new tennis court net
- Repaired storm sewer 100 block Clark St., hole in tile
- Repaired storm sewer in front of 1004 S. State, hole in storm tile
- Put asphalt down several places in town
- Cut limbs & brush, put millings down in several alleys
- Have a bid for Ellsworth St. storm sewer Brown Construction. Gave estimate to Seth Miller at Westville Schools. We are requesting the high school pay for this work.
- Cleaned gutters on E. Oak St.
- Took suction vac to Springfield to have serviced
- Sandblasting completed to curbs through town, will paint once the paint arrives (it is on order)
- Suggest evaluating the concession stand to add plexiglass to cover serving window, reduce cost and loss of temperature in the concession
- Widened "No Name", will have tar and chipped
- Repaired blower, pull rope
- Had concession stand A/C unit cleaned & filter changed

**Work Orders:**

JULIE CALLS	<u>39</u>	Gas & Water	<u>11</u>	Water W/O	<u>20</u>	Gas W/O	<u>2</u>
Odor Calls	<u>8</u>	CO Calls	<u>1</u>	Public Works	<u>19</u>		